



Government Of West Bengal
Office Of The Divisional Fire Officer, Bankura
West Bengal Fire & Emergency Services
Purulia Fire Station, Ranchi Road, Purulia, Pin:- 723101

Memo no.: IND/WB/FES/20182019/24634

Date: 08-09-2023

From:
Divisional Fire Officer, Bankura
West Bengal Fire & Emergency Services

To: SHAMAYITA CONVENT SCHOOL
MOUZA MARAYA, PLOT NOS 715, 1716, 1717, 1725, 1727, NO 517, PO AMARKANAN, PS GANGAJOLGHATI, DT
BANKURA PIN 722133.

Sub: Renewal of Fire Safety Certificate for an existing construction of G+II storied building under group Educational building in the name & style as "Shamayita Convent School" at the premises of Maraya, Amarkanan, Gangajolghati, Bankura - 722133.

This is in reference to your application no. 0125191237800099 dated 01-09-2023 regarding the Renewal of Fire Safety Certificate for an existing construction of G+II storied building under group Educational building in the name & style as "Shamayita Convent School" at the premises of Maraya, Amarkanan, Gangajolghati, Bankura - 722133.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

1. Driveway must be free of any type of obstruction for easy movement of Fire appliances. No parking will be allowed on the Driveway.
2. The interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.
3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear them, particularly lines above false ceiling & ducts.
5. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable of the Building.